

PROJECT

**מעבדת חומרים מרוכבים  
בניין וולפסון**

TITLE

**ETHYLENE SUPPLY SYSTEM PFD**

DRAWING NUMBER

REVISION

TAU 2401-02

P01

Date

04/07/2017

Job Number

TAU 2401

Scale

NTS@ A3

Drawn

Tanya Galkin

Checked











Mahmud Fadila

Approved

Ziad Nasser

STATUS  REVIEW  BID  CONSTRUCTION

**LEGEND**

 AUTOMATIC VALVE	 DUAL STAGE PRESSURE REGULATOR	 PRESSURE INDICATOR	 FLAME ARRESTER
 DIAPHRAGM VALVE	 PRESSURE SAFETY VALVE	 FUME HOOD VALVE	 EXCESS FLOW VALVE
 SINGLE STAGE PRESSURE REGULATOR	 GAS LEAK DETECTOR		

**הערות:**

- כל הצנרת מחוברת ע"י ריתוך.
- במקרים בהם נדרש חיבור בין צנרת לברזים או אבזרים החיבור יהיה מסוג VCR.